

## HEALTHCARE SAFETY INSPECTION

**Facility/Location:** \_\_\_\_\_

**Inspected By:** \_\_\_\_\_ **Date:** \_\_\_\_\_

STORAGE AREAS	YES	NO	HAZARD	CORRECTIVE ACTION	Initial & Date
1. Has a designated person been appointed to inspect safety issues in these areas?					
2. Floors are free of tripping hazards and well maintained?					
3. Are aisles free of trash and other debris and work areas maintained in an orderly manner?					
4. Adequate lighting and ventilation, either mechanical or gravity in all areas?					
5. Is the area clear of prohibited items? (Combustibles)					
6. Hazard Communication Program & MSDS training is complete for chemicals in this area?					
7. Are the MSDS accessible to employees during all working hours?					
8. Any bulged or dented cans?					
9. All chemicals are properly labeled?					
10. Chemical storage locked?					
11. Each inside storage area is marked as a no smoking area?					

**Workforce Safety & Insurance**

*www.WorkforceSafety.com*

12. All cautions signs are permanently marked for Hydrogen, bulk oxygen, storage cabinets, etc.?					
13. Combustible waste material such as oily rags and paint rags are stored in covered metal containers and disposed of daily?					
14. Piping systems, including tubing, flanges, bolting, gaskets, valves, fittings, and all pressurized parts containing flammable and combustible liquids meet the requirements of NFPA 30?					
15. Openings to rooms and buildings are provided with non-combustible, liquid-tight, raised sills or ramps that are at least four inches high or are otherwise designed to prevent the flow of liquids to adjoining areas?					
16. Has a personal protective equipment assessment been completed and documented?					
17. Proper type and number of fire extinguishers available?					
18. Door closer operable? a) Positive latch?					
19. Are stairwells, exit doors and emergency egresses accessible as well as free of obstructions?					
20. Is there a visible sign indicating the location of the eyewash above the station?					
21. Unsafe equipment taken out of use or tagged?					

**Workforce Safety & Insurance**  
*www.WorkforceSafety.com*

22. Is electrical equipment grounded with three-pronged plugs or protected by a ground-fault circuit interrupter (GFCI)?					
23. All trash receptacles are fire rated?					
24. Overhead items secured and heavy objects below eye level?					
25. Storage no more than 24" from the ceiling and 18" from a sprinkler head?					

**Management Signature** \_\_\_\_\_

**Date** \_\_\_\_\_